

Chlorate Working Group

Drinking Water Treatment

V0 1

May 2016



Why Our journey


Jan 2015:

- 23,000 people on a BWN
- 121 WSZs on RAL
- 49% UFW
- Over 33% of our WTPs do not have 15% headroom

What brought us to this point:

- Constrained funding leading to underinvestment
- Fragmented industry structure (31LAs)
- Inconsistent O&M standards
- Aging and poor quality infrastructure

The Challenge



Current:

- Priority – reduce OPEX
- Investment – driven by EU Directives
- No long term strategies
- Limit understanding of risk


Service
improvement

Effective decision making:

- Evidence-lead decisions
- Asset intelligence (better data)

| Ra w Water | | | | Filtration | | | | | | | Disinfection | |
|-----------------|------------|------------|-----------|------------|----------|------------|-----------|-----------|------------|-----------|--------------|------------|
| Category | Sources | CFC | % | SSF | Mem/Cart | RGF | GAC | Mang | Total | % | Chlorine | UV |
| G1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1 | 0 |
| G2 | 5 | 0 | 0 | 0 | 0 | 0 | 0 | 1 | 1 | 20 | 5 | 1 |
| G3 | 433 | 5 | 1 | 0 | 1 | 51 | 2 | 10 | 64 | 15 | 372 | 110 |
| G4 | 33 | 0 | 0 | 0 | 0 | 6 | 2 | 0 | 8 | 24 | 30 | 11 |
| G5 | 45 | 4 | 9 | 1 | 2 | 9 | 3 | 0 | 15 | 33 | 42 | 18 |
| S1 | 2 | 0 | 0 | 1 | 0 | 0 | 0 | 0 | 1 | 50 | 2 | 0 |
| S2 | 236 | 75 | 32 | 30 | 5 | 91 | 7 | 1 | 134 | 57 | 231 | 50 |
| S3 | 168 | 104 | 62 | 22 | 1 | 114 | 6 | 4 | 147 | 88 | 164 | 26 |
| Subtotal | 406 | 179 | 44 | | | | | | 282 | 69 | | |
| Total | 923 | 188 | | 54 | 9 | 271 | 20 | 16 | 370 | 40 | 847 | 216 |


What



What



WTP size (MLD)




Current:

- 860+ WTPs
- 70% of WTPs < 1.0MLD
- 31% of WTPs abstract from surface water sources
- 70% of population supplied from WTPs abstracting from surface water

Scottish Water:

- 400 WTPs (2002) → 235 WTPs (2013) [41% ↓]

WTP Source Category




| Region | 2015 | PRW1 Option 3 |
|---------------|------------|---------------|
| Southern | 548 | 184 (66% ↓) |
| East Midlands | 226 | 53 (76% ↓) |
| North West | 161 | 84 (48% ↓) |
| Total | 935 | 321 |

DRAFT

The Disinfection Strategy

Water Treatment Process Chain




Application of Disinfection Technologies

| Consideration | Chlorine | Chloramines | Ozone | Chlorine Dioxide | UV |
|------------------------------------|----------|-----------------------------|--------------------------------|--------------------------------|---------------------------------|
| Complexity of technology | Low | Low | High | Medium | Medium |
| H&S | Low * | Medium | Medium | High | Low |
| Efficacy against bacteria | Good | Good | Good | Good | Good |
| Efficacy against viruses (Adeno) | Good | Medium | Good | Good | Medium |
| Efficacy against protozoa (Crypto) | Poor | Poor | Good | Poor | Good |
| By-product formation | THM, HAA | NDMA | Bromate | Chlorite, Chlorate | |
| pH dependency | High | High | None | Medium | None |
| Persistent residual | High | High | None | Medium | None |
| O&M | Low | Moderate | High | Moderate | Moderate |
| Applicability in Ireland | | Increased metal corrosivity | Very large Ct required at <5°C | Very large Ct required at <5°C | UVT > 70% Turbidity ≤1.0 NTU |

* High H&S concerns for chlorine gas

| Primary disinfectant | Log Inactivation for <i>Cryptosporidium</i> | Required Ct (mg.min/L) at water temperature of 5°C |
|----------------------|---|--|
| Ozonation | 3.0 | 47 |
| Chlorine dioxide | 3.0 | 1,288 |

Process Decision Chart




Bacterial and Viral Compliance Criteria

A) Bacterial and Viral Non-compliance

- A chlorination disinfection process does not achieve Target Ct determined in [Steps A.1: Chlorination Validation Calculation](#), resulting in the treatment plant not reaching the total log credits required.
- The monitoring or operational requirements specified in [Step A.2](#) are not met or exceeded.
- Incorrect monitoring procedures are used (eg, inadequate sampling, incorrect standardisation of metering equipment, or analyses not carried out by a laboratory recognised for the purpose).

Primary Disinfection Option 1 – Chlorine only



Step A.1 - Bacterial and Viral Log Credit Compliance Requirements – Chlorination


- Calculate target Ct and Effective Ct



Distribution
factor =0.1



Distribution
factor =0.5




Disinfection - Chlorination Validation Calculation

Plant Details

| | |
|--------------------------|-------------------------------|
| Scheme Name: | Example Scheme |
| Treatment Plant Name: | Example Water Treatment Plant |
| Water Supply Zone Code: | WSZ000 |
| Maximum flow | 200.00 m ³ /hr |
| Calculation prepared by: | A.N. Other |
| Date: | 31/10/2014 |

Contact Tank Shapes



Target Ct

| | | |
|-----------------------------------|----------------------|----------|
| Source: | Surface Water (Lake) | |
| Maximum pH: | 8.20 | |
| Minimum Temperature: | 5.00 | °C |
| Maximum Filtered Water Turbidity: | 0.4 | NTU |
| Minimum Ct | 15 | mg.min/l |
| pH Factor | 1.3 | |
| Temperature Factor | 1.2 | |
| Turbidity Factor | 1 | |
| Target Ct | 23.40 | mg.min/l |

Effective Ct - Contact Tanks

| Contact Tank | No. 1 | No. 2 |
|---|---------------|----------------|
| Tank shape | Rectangular * | Circular ** |
| Internal length (L) * | 10.00 | m |
| Internal width (W) * | 10.00 | m |
| Internal diameter (D) ** | | m |
| Minimum depth (d) | 3.00 | m |
| Tank volume | 300.00 | m ³ |
| Flow distribution | Poor | Average |
| Distribution factor | 0.3 | 0.5 |
| Effective contact time (t) | 27.00 | minutes |
| Minimum free chlorine concentration after (t) | 0.8 | mg/l |
| Effective Ct after (t) | 21.60 | mg.min/l |

Effective Ct - Pipelines

| Pipe | No. 1 | No. 2 |
|---|--------|----------------|
| Internal diameter | 0.25 | m |
| Length | 300.00 | m |
| Pipe volume | 14.73 | m ³ |
| Effective contact time (t) | 4.42 | minutes |
| Minimum free chlorine concentration after (t) | 0.62 | mg/l |
| Effective Ct after (t) | 2.74 | mg.min/l |

Total Effective Ct after (t) 24.34 mg.min/l

Instructions : 1) Enter site specific data into blue cells. 2) Grey cells, select from drop down box.
3) Total effective Ct after (t) must be greater than target Ct.

Step A.2 - Bacterial and Viral Log Credit Compliance

Criteria – Chlorination

- To obtain 4.0 bacterial and viral log credits for chlorination used as primary disinfection process, the following requirements must be met during periods when treated water is being produced:
 - All water must pass through the full chlorination (primary disinfection) process [no bypass or mixing of water];*
 - Effective Ct must exceed target Ct (IW Chlorination Validation Calculation Worksheet) at all times;*
 - Measurement of free chlorine of the water leaving the contact tank must satisfy the following conditions:*
 - Shall be greater than or equal to 0.5mg/L for the duration of any three-minute period.
 - Measurement of turbidity of the water entering the contact tank must satisfy the following conditions:*
 - Shall be less than or equal to 1.0 NTU for the duration of any three-minute period;
 - Treated water turbidity shall not exceed the raw water turbidity for the duration of any three-minute period; and
 - Shall not exceed 2.0 NTU in any sample
 - Measurement of pH of the treated water entering the contact tank must satisfy the following conditions:*
 - Shall be less than or equal to maximum design pH for the duration of any fifteen-minute period.
- Bacterial compliance monitoring requirements for chlorination (primary disinfection) are as follows (separation between data records must be less than 1-minute):

| Parameter | Location | Frequency | Critical Control Point | Alarm | Compliance duration |
|----------------|--|------------|---|------------------------|----------------------|
| Turbidity | Treated water | Continuous | >1.0NTU | >0.8NTU | Any 3-minute period |
| | Treated water | Continuous | >2.0NTU | >1.5NTU | Any 1-minute period |
| | Treated water | Continuous | Treated water turbidity > raw water turbidity | | Any 3-minute period |
| Total chlorine | Treated water (before contact tank) | Continuous | <0.4mg/L | >0.5mg/L | Any 3-minute period |
| Free chlorine | Disinfected water (after contact tank) | Continuous | <0.5mg/L | >0.6mg/L | Any 3-minute period |
| pH | Treated water | Continuous | > Maximum design pH | >0.8 Maximum design pH | Any 15-minute period |
| Flow | Treated water | Continuous | >maximum design flow m ³ /hr | | Any 15-minute period |

Protozoal Compliance Criteria

Principle

- *Cryptosporidium* is the most infectious and most difficult protozoan to remove or inactivate.
- The protozoal compliance criteria are constructed on the principle that if the treatment process deals successfully with *Cryptosporidium*, they will also deal successfully with other protozoa.

IW Protozoal Compliance Criteria

- **Cumulative log credit approach** - acknowledges any additive effect of successive different treatment processes on the removal/inactivation of protozoa where more than one treatment process is used.
- Uses overseas data, chiefly from the United States Environmental Protection Agency (USEPA) (USEPA 2006a), on the **log-removal/inactivation efficacy (a measure of the percentage of organisms removed/inactivated)** of *Cryptosporidium* for a range of treatment processes.
- **Specifies the use of validated equipment** (where appropriate), **monitoring programmes** and **treatment performance measures**.

B) Protozoal Non-compliance

- A treatment process does not satisfy the conditions required to achieve the log credit specified in **Steps B.1.1 or B.1.2: Log credit assessment**, resulting in the treatment plant not reaching the total log credits required.
- The monitoring or operational requirements specified in **Steps B.3.1, B.3.2, B.3.3, B.3.4, B.3.5, B.3.6 or B.3.7** are not met or exceeded.
- Incorrect monitoring procedures are used (eg, inadequate sampling, incorrect standardisation of metering equipment, or analyses not carried out by a laboratory recognised for the purpose).

Step B.1.1 - Protozoal Compliance Requirements

- **Option 1** (Inadequate monitoring)
 - *Characteristics of source are assessed against catchment and groundwater categories.*

Table D.1: Log credit requirements for different catchments and groundwater categories

| | Groundwater | Surface water | Log credit requirement |
|-----------------------------|--|---|------------------------|
| Removal and/or Inactivation | G1 Low risk (no microbiological contamination) – sealed bored well with source protection, water drawn from deeper than 30m | Not applicable | 0 |
| | G2 High risk (with microbiological contamination) – sealed bored well with source protection, water drawn from deeper than 30m | Not applicable | 2 |
| | G3 High risk (with microbiological contamination) – sealed bored well with source protection, water drawn between 10m to 30m (Groundwater default) | S1 Upland catchment - no agricultural activity in immediate vicinity or upstream | 3 |
| | G4 High risk (with microbiological contamination) - spring or bored well, water drawn <10m, in upland catchment with low concentration of cattle, sheep, horses or humans in immediate vicinity or upstream | S2 Upland catchment - low concentration of cattle, sheep, horses or humans in immediate vicinity or upstream (Surface water default) | 4 |
| Removal + Inactivation | G5 High risk (with microbiological contamination) - spring or bored well, water drawn <10m, in lowland catchment with high concentration of cattle, sheep, horses or humans in immediate vicinity or upstream or waste treatment outfall upstream | S3 Lowland catchment – high concentration of cattle, sheep, horses or humans in immediate vicinity or upstream or waste treatment outfall upstream | 5 |

Step B.2 - Protozoal Treatment Options

Table D.3: Protozoa treatment options and credits


| Treatment | Log credit |
|---|---|
| Filtration (physical removal) | |
| Coagulation, flocculation, clarification and rapid gravity filtration | 3.0 |
| • Additional log credit for enhanced individual filtration | 1.0 |
| Slow sand filtration | 2.5 |
| Direct filtration * | 2.5 |
| Membrane filtration * | Log credit demonstrated by challenge testing and verified by direct integrity testing |
| Cartridge * | 2.0 |
| Bag * | 1.0 |
| Disinfection (inactivation) | |
| UV | Dose dependent (max 3.0) |

* selection of these filtration processes should be referred to Asset Strategy (Water Treatment) before proceeding with procurement


Note:

- Must consistently meet Steps B.3.1, B.3.2, B.3.3, B.3.4, B.3.5 or B.3.6 protozoa treatment compliance criteria (operational requirements); and
- Total inactivation log credit must not exceed 3.0.

Primary Disinfection Option 2 – Chlorine only



Primary Disinfection Option 3 – Chlorine + UV



WTPs with chlorine gas

| County | No. of WTPs | Chlorine gas | County | No. of WTPs | Chlorine gas |
|-------------|-------------|--------------|--------------|-------------|--------------|
| Carlow | 14 | 3 | Limerick | 39 | |
| Cavan | 17 | | Longford | 7 | |
| Clare | 17 | | Louth | 13 | 2 |
| Cork | 175 | | Mayo | 21 | 4 |
| Cork City | 1 | | Meath | 59 | 6 |
| DLR | 3 | | Monaghan | 13 | 3 |
| Donegal | 39 | | Offaly | 28 | |
| Dublin City | 3 | 2 | Roscommon | 13 | 3 |
| Fingal | 2 | | Sligo | 7 | 4 |
| Galway | 34 | | South Dublin | 1 | |
| Galway City | 1 | | Tipperary | 56 | 3 |
| Kerry | 63 | | Waterford | 115 | |
| Kildare | 7 | | Westmeath | 4 | |
| Kilkenny | 22 | 2 | Wexford | 34 | 5 |
| Laois | 26 | 2 | Wicklow | 55 | 1 |
| Leitrim | 4 | 2 | | | |
| | | | Total | 893 | 42 |

Example: Sodium Hypochlorite vs chlorine gas

- Deficiencies of existing chlorine gas disinfection system:
 - Manual dose adjustment (no flow proportional or chlorine residual control)
 - No automatic chlorinator changeover
 - Gas cylinder changeover panel no longer being manufactured
 - CAPEX upgrade cost = €108,803
- New Sodium Hypochlorite disinfection system:
 - CAPEX upgrade cost = €74,544

Disinfection By-products

Chlorination By-products

- Organic
 - *Reaction between chlorine and organic matter in water*
 - *THMs, HAAs*

- Inorganic
 - *Arise due to production and storage*
 - *Bromate, chlorate and chlorite*

Sodium Hypochlorite Degradation



- IW Standards
 - *Concentration $\leq 10\%$*
 - *Storage < 50 days*

Table 4.2 Illustrative examples of chlorine decomposition in hypochlorite solution @ 20°C

| Initial concentration | After 20 days | After 100 days |
|-------------------------|---------------|----------------|
| 15% available chlorine | 13% | 10% |
| 13% available chlorine | 12% | 8% |
| 10% available chlorine | 9% | 8% |
| 6.5% available chlorine | 6.2% | 6% |


Standards for chlorine chemicals

Table 4.5 *Chlorination chemical standards: limits for chlorite, chlorate and bromate*

| Contaminant | Maximum contaminant per mg Cl ₂ dosed | | |
|-------------|--|---|--|
| | Chlorine gas *IS EN 937: 1999 | Commercial Sodium Hypochlorite *IS EN 901:2007 | Sodium Hypochlorite from OSE *IS EN 14805:2008 (salt) |
| Chlorite | Insignificant | Insignificant | Insignificant |
| Chlorate | Insignificant | 0.042 mg | Insignificant |
| Bromate | Insignificant | 2.5 to 5 µg | **1.2 to 2.4 µg |


* IS EN = European standard incorporated into Irish standards, where a range is given this relates to the different product specifications allowable under the standard.

THM Reduction Strategy



Optimise disinfection:

1. Reduce contact time
2. Reduce chlorine dose



50% reduction in THMs
formed at primary
disinfection stage